

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6 DFS/MS/School/2020/SZ/ 444

Dated: 26 / 10 / 2020

**FIRE SAFETY CERTIFICATE**

Certified that the **YMCA Primary School** located at Nizamuddin East New Delhi, comprised of ground plus one upper floor was issued FSC by this department vide letter No. F.6/MS/DFS/2000/626 dated 30/03/2000 for Ground + 01 Upper Floor. The premises was re-inspected by officers concerned of this department on 20/10/2020 in the presence of Mr. Babu. P of the school and observed that school management has constructed 2<sup>nd</sup> & 3<sup>rd</sup> floor in the existing building. The school building now comprised of **ground plus three upper floors** have complied with the fire prevention and fire safety arrangements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class **"Educational Building, Group-B"** as above with effect from 26 / 10 / 2020 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26 / 10 / 2020 at New Delhi by

  
(Arun Garg)  
Director  
Delhi Fire Service

Copy to: -

1. Manager, **YMCA Primary School** located at Nizamuddin East New Delhi.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry."